

LOCATION 630 Carolina Ave CITY Castonia
BETWEEN Jackson STREET & Florida STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>		<u>Tied over EXT 3/4</u>	
MAIN TO PROP. LINE					<u>plastic Service to EXT</u>	
PROP. LINE TO BLDG.					<u>2" Bm man</u>	

ENTERS:

BRANCHED INTO:

TAP SIZE: 5/8 PRESSURE 20 P.S.I. INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 44 Hrs. By CP

MAIN-SIZE 2' C.I. ☐ BARE STEEL ☒ COATED STEEL ☐ PLASTIC ☐ YEAR INSTALLED P30

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING 16 TOTAL ANODES 1* 0 17* 0 L.R. #

REMARKS: Bonded to EXT 17th Anode



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY