

LOCATION 702 Carolina Ave. CITY CAS?  
BETWEEN Carolina Ave. STREET & Townsend STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>55'</u>		<u>1-</u>	<u>18-98</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>50'</u>			


ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 122' From DOF  
Carolina Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION W. OF JACKSON Rd

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY