

LOCATION 807 CAROLINA AVE CITY GASTONIA

BETWEEN EDGEFIELD STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>110'</u>	<u>6-19-96</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>70'</u>			

ENTERS: 807 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 30 PSI _____ INCHES W.C. LOCATION 146' W OF C OF CAROLINA AVE


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SA

MAIN-SIZE 2" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1950

DEPTH: 4 FT. 6 IN. LOCATION 15' S OF C OF EDGEFIELD

"A" P/S READING .5 TOTAL ANODES 1# _____ 17# ☒ L.R. # 00311719

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY