

LOCATION 808 Carolina Ave. CITY Oaktonia  
BETWEEN Central Ave. STREET & Edgefield Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>126'</u>	<u>3-9-98</u>	<u>110' Existing</u>	<u>3/4 Pipe to Be</u>
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>36'</u>		<u>Retired</u>	<u>w/main</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>90'</u>			

ENTERS: 808

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 266' E of C of Edgefield Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 3 FT 0 IN LOCATION 15' N of C of Carolina Ave.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY