

LOCATION 902 Caroline Ave CITY Castroville
BETWEEN St. Michaels Ln STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	95'	11-4-02		
MAIN TO PROP LINE	5/8"	P	35'			
PROP LINE TO BLDG	5/8"	P	40'			


ENTERS 902 BRANCHED INTO
TAP SIZE 3/4" PRESSURE 600 PSI INCHES WC LOCATION 123' NW. of center of St. Michaels Ln

PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.A.
MAIN SIZE 4" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 17' SW. of center of Spoken Ave

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 327028

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	