

LOCATION 3708 Caroline Cherry Ct. CITY Castroville  
BETWEEN Golden Bell Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>		<u>10-22-07</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>				
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>				

ENTERS 3708 BRANCHED INTO  
TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 385' N. of park at Golden Bell Dr


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY J.G.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 3 FT 0 IN LOCATION 30' E. of center of Caroline Cherry Ct

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 34986

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	