

LOCATION	112 Carpenter ST.			CITY	Gastonia	
BETWEEN	Warren ST		STREET &	Dead End.		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	83'	10-7-95		
MAIN TO PROP. LINE	3/4"	P	25'			
PROP. LINE TO BLDG.	3/4"	P	58'			

ENTERS: 112 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 403' S. of center of Warren ST


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Hefner

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION 11' W. of center of Carpenter ST

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 504375

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY