

LOCATION 210 Carpenter St CITY Castroville

BETWEEN Wagon Ave STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>72'</u>	<u>10-4-00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>43'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>29'</u>			

ENTERS 210 BRANCHED INTO

TAP SIZE 3/4" PRESSURE _____ PSI _____ INCHES W C LOCATION 750' S. of center of Wagon Ave.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.L.H.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED _____

DEPTH 3 FT 0 IN LOCATION 14' E. of center of Carpenter St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 915174

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	