

LOCATION 301 Carpenter St CITY GA STAMPA
BETWEEN Warren Ave STREET & Dead End STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>37'</u>	<u>12-2-96</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>31</u>			

ENTERS 301 BRANCHED INTO
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 1237' S. of center of Warren Ave

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S. Hunt Smith
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED _____
DEPTH: 3 FT 0 IN LOCATION 14' w. of center of Carpenter St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 676111

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		