

LOCATION 121 Carrie Elizabeth CT CITY Castroville

BETWEEN Lowell Bethesda Rd. STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	126'	11-4-97		
MAIN TO PROP. LINE	3/4"	P	40'			
PROP. LINE TO BLDG.	3/4"	P	86'			

ENTERS: 121 BRANCHED INTO:

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 600' E. of center of

Lowell Bethesda Rd.


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS. BY S. Huggins

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1989

DEPTH. 3 FT 0 IN. LOCATION 18' S. of center of Carrie Elizabeth CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 756056

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY