

LOCATION 613 CARSON Rd. CITY GASTONIA
 BETWEEN Archie Whitesides STREET & Laura Woods Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>286'</u>	<u>8-22-02</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>53</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>233'</u>			


ENTERS 613 BRANCHED INTO 0
 TAP SIZE 3/8" PRESSURE 60 PSI _____ INCHES W C LOCATION 189' E of C of Laura Woods Dr.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN-SIZE 6" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED ?

DEPTH _____ FT _____ IN _____ LOCATION 18' S of C of CARSON Rd.

"A" P/S READING 1.1 TOTAL ANODES 1# 0 17# 0 I.R. # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	<u>Plastic</u>