

LOCATION 772 CARSON Rd. CITY GASTONIA

BETWEEN Justland Ln STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>127'</u>	<u>9-23-98</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>54'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>73'</u>			

ENTERS: 772 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 1240' E. of center of

Justland Ln


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huffstaller

MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 14' S. of center of Carson Rd.

"A" P/S READING 1.4 TOTAL ANODES 1# 0 17# 0 L.R. # 2046983

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY