

LOCATION 1430 Castle Ct. (C+D) CITY Castroville
BETWEEN Northwest Blvd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>250'</u>	<u>9-21-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>15'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>235'</u>			

ENTERS 1430 C+D BRANCHED INTO
TAP SIZE 3/4" PRESSURE 40 PSI INCHES W C LOCATION 255' S. of center of Northwest Blvd.

PRESSURE TEST @ 100 PSI FOR 114 HRS BY S.H.
MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 3 FT 0 IN LOCATION 20' E. of center of Castle Ct.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L R # 0064064

REMARKS

