

LOCATION 602 Castle woodCITY GastoniaBETWEEN SterlingSTREET & Wind wood

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	80'	1-7-94		
MAIN TO PROP. LINE	3/4	P	17'			
PROP. LINE TO BLDG.	3/4	P	63'			

ENTERS: 602BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60


P.S.I.

INCHES W.C.

LOCATION

E. Side of 602PRESSURE TEST: @ 100 psi For 16 Hrs. By BCMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1990DEPTH: 3 Ft. In. LOCATION 17' S of C' of Castle wood"A" P/S READING Plastic TOTAL ANODES 1# ~ 17# ~ L.R. # 448

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY