

LOCATION	701 Castlemore Dr.			CITY	Gastonia	
BETWEEN	STERLING DR		STREET @	Dead End		STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	48'	5-7-96		
MAIN TO PROP. LINE	3/4"	P	30'			
PROP. LINE TO BLDG.	3/4"	P	68'			

ENTERS: 701 BRANCHED INTO:

TAP SIZE: 1/2	PRESSURE 60 P.S.I.	INCHES W.C.	LOCATION 90' E. of center of Sterling Dr
---------------	--------------------	-------------	--


PRESSURE TEST: @ 105 psi For 1/4 Hrs. By S. H. H. H.

MAIN-SIZE 2"	C.I. —	BARE STEEL —	COATED STEEL —	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED 1995
--------------	--------	--------------	----------------	---	---------------------

DEPTH: 3 Ft. 0 in. LOCATION 17' S. of center of Castlemore Dr

"A" P/S READING P	TOTAL ANODES 1* 0 17* 0	L.R. # 226564
-------------------	-------------------------	---------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY