

LOCATION 156 Cedar St CITY GASTONIA
BETWEEN Cox Dr. STREET & 3rd St. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>66'</u>	<u>5-6-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>56'</u>			

ENTERS: 156 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 135' S of Cox Third St.

PRESSURE TEST: @ 100 psi For 14 Hrs. By RL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1962
DEPTH: 3 Ft. 0 In. LOCATION 11' E of Cox Cedar St.

"A" P/S READING 1.2 TOTAL ANODES 1* 17* L.R. # 181505

REMARKS: New Plastic Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser PLASTIC</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY