

LOCATION 157 Cedar St. CITY Gastonia
BETWEEN Third St. STREET & Cox Dr. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>100'</u>	<u>2-11-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>28'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>72'</u>			

ENTERS: 157 BRANCHED INTO: 0
TAP SIZE: 3/8 PRESSURE 40 P.S.I. INCHES W.C. LOCATION 89' S of 3rd St.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1962
DEPTH: 3 Ft. 0 In. LOCATION 11' E of 1st Cedar St.

"A" P/S READING 1.3 TOTAL ANODES 1# 17# L.R. # 063665

REMARKS: New 3/4 Plastic Service with A Road Bore.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY