

LOCATION 2206 Cedar St. CITY CANTONIA
BETWEEN MIDWAY Dr. STREET & FAIRWAY St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>	<u>8-23-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>52'</u>			

ENTERS: 2206 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 63' W of C of Midway Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 13' N of C of Cedar St.

"A" P/S READING Plastic N/A TOTAL ANODES 1* 17* L.R. # 412 112

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY