

LOCATION

2207 Cedar St.

CITY

Castro

BETWEEN

Midway Dr.

STREET &

Fairway Dr.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	18'	8-22-97		
MAIN TO PROP. LINE	3/4"	P	8'			
PROP. LINE TO BLDG.	3/4"	P	10'			

ENTERS:

2207

BRANCHED INTO:

TAP SIZE:

3/4"

PRESSURE

600

PSI

INCHES W.C.

LOCATION

76' S. of center of
Cedar St.

PRESSURE TEST: @

100

PSI

FOR

1/4

HRS

BY

S. Huggins

MAIN-SIZE

3/4"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1995

DEPTH:

2 FT

0 IN.

LOCATION

86' SW. of center of Midway Dr.

"A" P/S READING

P

TOTAL ANODES 1#

0


17#

0

L.R. #

565649

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E

ENG. DEPT. USE ONLY