

LOCATION 613 CEDAR GROVE DR CITY GASTONIA

BETWEEN OAKWOOD CIR STREET & Robinson Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>95</u>	<u>P</u>	<u>8-18-80</u>		
MAIN TO PROP LINE	<u>"</u>	<u>29</u>	<u>"</u>			
PROP LINE TO BLDG	<u>"</u>	<u>66</u>	<u>"</u>			

ENTERS SAME BRANCHED INTO —

TAP SIZE 3/4" PRESSURE 60 PSI — INCHES W C LOCATION 12' NORTH OF OAKWOOD CIRCLE


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY MD

MAIN-SIZE 2" C I — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 97

DEPTH 3 FT 0 IN LOCATION NORTH SIDE OF OAKWOOD DR.

"A" P/S READING P TOTAL ANODES 1# — 17# — LR # —

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	
P/S Pipeline Lead White Existing Main	<u>E</u>	