

LOCATION 620 Cedar Grove Dr CITY Castroville

BETWEEN Oakwood Ctn STREET & Robinson Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>85'</u>	<u>11-15-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>75'</u>			

ENTERS: 620 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W C LOCATION 201' N. of center of

Oakwood Ctn


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY S. Huffstetter

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 0 IN LOCATION 13' E. of center of Cedar Grove Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 770299

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY