

LOCATION 402 CENTER ST. CITY EAST.

BETWEEN GREEN circle Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>68'</u>		<u>8-4-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>36'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>32'</u>			

ENTERS: SAME BRANCHED INTO: 1001 Green circle Dr.

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 127' From @ OF

Green cir Dr.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN LOCATION N. OF CENTER ST.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY