

LOCATION 3712 Chapel Grove sch. Rd. CITY Gastonia
BETWEEN Starland Dr. STREET & Brandywine Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>117'</u>	<u>11/29/00</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>20'</u>	<u>11/29/00</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>97'</u>	<u>11/29/00</u>		

ENTERS 3712 Chapel Grove sch. Rd. BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W C LOCATION 112' north of
center of Brandywine Dr.

PRESSURE TEST @ 60 PSI FOR 44 HRS BY D. Ward

MAIN SIZE 8" C I _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1966

DEPTH 3' FT 0" IN LOCATION 12' East of center of Chapel Grove sch. Rd.

"A" P/S READING 1.0 TOTAL ANODES 1# Ø 17# Ø LR # 1100125

REMARKS New 3/4" plastic service

