

LOCATION 3641 Chapelwood Dr. CITY Costa Mesa  
BETWEEN Dead end STREET & Chapelwood STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>70'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>65'</u>			<u>7/29/92</u>


ENTERS: 3641 BRANCHED INTO: 0  
TAP SIZE: 3/4 Sav. PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EB  
MAIN-SIZE 24 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 10-15-63

DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING i7 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY