

LOCATION 4307 Chelsea way CITY Gastonia
BETWEEN Gaston Day School Rd STREET & Dead end STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	81	10-15-96		
MAIN TO PROP. LINE	11	11	6			
PROP. LINE TO BLDG.	11	11	75			

ENTERS: 4307 BRANCHED INTO: 0
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 355 w of c of


_____ Gaston day school Rd
PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY BC

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1989

DEPTH: 3 FT. IN. LOCATION 13' S of cot chelsea way

"A" P/S READING Plastic TOTAL ANODES 1# - 17# - L.R. # 0588162

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>OK</u>	<u>P</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY