

LOCATION 4300 Chelsea way Rd. CITY GASTONIA

BETWEEN Stoneligh STREET & Lismore STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLastic</u>	<u>81'</u>	<u>3-2-98</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>41'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 521' FT EAC of Gaston Day

School Rd


PRESSURE TEST: @ 100 PSI FOR 1/4 hrs HRS. BY MDS Smitty

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1998

DEPTH: 3 FT. - IN. LOCATION 12' SOUTH C. of Chelsea way Rd

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY