

LOCATION 4330 Chelsea Way CITY GASTONIA
BETWEEN GASTON Day School Rd. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>64'</u>	<u>10-30-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>29'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>35'</u>			

ENTERS: 4330 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 600 P.S.I. INCHES W.C. LOCATION 267' w of l of Gaston Day School Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1989

DEPTH: 2 Ft. 6 In. LOCATION 11' S of l of Chelsea way.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 17# L.R. # 533306

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY