

LOCATION 1200 Chestnut CT. CITY Canton  
BETWEEN Devonshire CT. STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>88'</u>	<u>4-18-03</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>10'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>78'</u>			

ENTERS 1200 BRANCHED INTO  
TAP SIZE 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 7' S. of center of Chestnut CT

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY Saty  
MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1991  
DEPTH 3 FT 0 IN LOCATION 48' W. of center of Cal. de. Sta

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 45766

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	