

LOCATION 211 N. Cherry St. CITY EAST
BETWEEN AIRLINE STREET & RANKIN STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	63'		4 - 4	-96
MAIN TO PROP. LINE	"	"	4'			
PROP. LINE TO BLDG.	"	"	59'			

ENTERS: 211 N. Cherry BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION South of 211

PRESSURE TEST: @ 100 psi For 14 Hrs. By GL
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 96
DEPTH: 3 Ft. _____ In. LOCATION W. Side of N. Cherry

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY