

LOCATION 413 CHERRY ST. CITY GAST.  
BETWEEN GRANITE STREET & LINCOLN STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	44'		5-1-96	
MAIN TO PROP. LINE	1"	"	5'			
PROP. LINE TO BLDG.	1"	"	39'			

ENTERS: 413 CHERRY ST BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION W. of 413


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By GK

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 96

DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION W. S. side Cherry St.  
N. " " Granite Ave.

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY