

LOCATION 213 N. Chester St. CITY GASTONIA

BETWEEN W. RANKIN ST. STREET & Long Ave STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	155'	1-16-02		
MAIN TO PROP LINE	3/4"	P	5			
PROP LINE TO BLDG	3/4"	P	150'			

ENTERS 213 BRANCHED INTO _____

TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 368' S. of center of W. Rankin Ave


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.G.H.

MAIN-SIZE 4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN LOCATION 16' E of center of N. Boyce St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	