

LOCATION 2421 N. Chester St. CITY Gastonia
BETWEEN Tutip Dr. STREET & Grier Beam Blvd. STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|-------------|----------|-------------|-----------|-----------------|---------|
| MAIN TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>147'</u> | | <u>10-11-99</u> | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>1'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4"</u> | <u>P</u> | <u>146'</u> | | | |

ENTERS: Same BRANCHED INTO

TAP SIZE: PRESSURE _____ PSI _____ INCHES W C LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY B.B.

MAIN-SIZE _____ C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____


DEPTH: FT IN LOCATION

"A" P/S READING 1.5 TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS:

Retire 1" Bare Service.

Renewal 3/4" Plastic



| Test Station | | |
|---|----------|---------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>S</u> | <u>11.95V</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |