

LOCATION S39 N. Chester ST CITY GASTON, N.C.

BETWEEN RANKIN ST STREET & ALLISON ST. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>130'</u>	<u>2-23-96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>50'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS: S39 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 711' S. of center of Allison Ave


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. H. H. H. H.

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1953

DEPTH: 2 Ft. 0 In. LOCATION 24' E. of center of N. Chester ST

"A" P/S READING .5 TOTAL ANODES 1# 0 17# 1 L.R. # 75649

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY