

LOCATION 907 N ChesterCITY Gastonia

BETWEEN

BoyceSTREET & 321

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>50' Plastic</u>	<u>12-14-91</u>		
MAIN TO PROP. LINE	<u>Ø</u>		<u>tied over</u>			
PROP. LINE TO BLDG.			<u>to C+W</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 152 West
of center of 321


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By K Hayes

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1991

DEPTH: 3 Ft. In. LOCATION 19 South of center of Davidson

"A" P/S READING 1.3 C+W TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY