

LOCATION 1204 N. Chester St

CITY Gastonia

BETWEEN Norment

STREET & New Way

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	72'		Retired 3/4" C+U with Main	
MAIN TO PROP. LINE	"	"	21'		purged with Air +	
PROP. LINE TO BLDG.	"	"	51'		Capped	

ENTERS: Same

BRANCHED INTO:

TAP SIZE: 3/4

PRESSURE 60 PSI

INCHES W.C.

LOCATION 36' East of N. Chester +

830' North of Norment

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BB

MAIN-SIZE 4"

C.I.

BARE STEEL

COATED STEEL

PLASTIC ☒

YEAR INSTALLED 1997

DEPTH: 4 FT. 6 IN.


LOCATION 36' East of N. Chester St.

"A" P/S READING

TOTAL ANODES 1# 17#

L.R. #

REMARKS: Retired + Renewed Service



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY