

LOCATION 1410 N. Chester CITY Gastonia
BETWEEN Caldwell STREET & New Way STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C+W</u>	<u>110'</u>	<u>Tied over 3/4"</u>	<u>Retired 3/4"</u>	<u>purged with</u>
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>16'</u>	<u>C+W to 4" C+W</u>	<u>service with</u>	<u>Air + capped</u>
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>99'</u>	<u>9-27-97</u>	<u>1 1/2 main</u>	

ENTERS: Same

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 36' East of N. Chester
177' South of Caldwell St.


PRESSURE TEST: @ 100 PSI FOR 4/4 HRS. BY BB

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1970

DEPTH: 4 FT. 0 IN. LOCATION 36' East of N. Chester

"A" P/S READING 1.7 TOTAL ANODES 1# -0- 17# -0- L.R. # _____

REMARKS: Tied over Existing 3/4" Service to 4" C+W main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY