

LOCATION 1506 + 1508 N. Chester St. CITY Gastonia
BETWEEN Caldwell STREET & Radio Dr. STREET


	SIZE	TYPE	1506 LENGTH	1508	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	63'	43'		Retired 3/4" CW + 3/4" Bare	
MAIN TO PROP. LINE	3/4	P	10'			services purged with Air + capped	
PROP. LINE TO BLDG.	3/4	P	53'				9-29-97

ENTERS: 1506 N. Chester BRANCHED INTO: 1508 N. Chester
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 126' North of Caldwell +
37' East of N. Chester

PRESSURE TEST: @ 100# PSI FOR 1/4 HRS. BY BB
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1970
DEPTH: 4 FT. 0 IN. LOCATION 37' East of N. Chester St.

"A" P/S READING 1.7 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Retired + Renewed 1506 + 1508 N. Chester St.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY