

LOCATION 1518 N. Chester St. CITY Gastonia  
BETWEEN Caldwell St. STREET & Radio Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C+W</u>	<u>160'</u>	<u>Tied over 160' of</u>	<u>Retired 3/4" stub</u>	
MAIN TO PROP. LINE				<u>3/4" c+w to Existing</u>	<u>with 1 1/2 main</u>	
PROP. LINE TO BLDG.				<u>4" C+W MAIN</u>	<u>purged with Air &amp; capped</u>	


ENTERS: 1518 N. Chester BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 232' N of Caldwell &  
37' East of Chester St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BR  
MAIN-SIZE 4" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1970

DEPTH: 4 FT. 0 IN. LOCATION ~~37'~~ 37' East of N. Chester St.

"A" P/S READING 1.5 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Tied over 3/4" service to 4" c+w main

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		