

LOCATION 2106 N. Chester St. CITY GASTON, N.C.

BETWEEN Rankin Lake Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	142'	8-14-98		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	132'			

ENTERS: 2106 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 178' E. of center of N. Chester St.


PRESSURE TEST: @ 100 PSI FOR 114 HRS. BY S. Huffstetler

MAIN-SIZE 6" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1964

DEPTH: 3 FT. 0 IN. LOCATION 19' N. of center of Rankin Lake Rd.

"A" P/S READING .9 TOTAL ANODES 1# 0 17# 0 L.R. # 2005014

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY