

LOCATION 2347 N Chester st (us 321) CITY GASTONIA  
BETWEEN Tulip D.R. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	191'			10/11/95
MAIN TO PROP. LINE	3/4"		15'			
PROP. LINE TO BLDG.	3/4"		176'			

ENTERS: 2347 (Quality Service) BRANCHED INTO:  
TAP SIZE: 3/8" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION Side of 2347


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

~~Stub~~ MAIN - SIZE 1" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1970

DEPTH: 1 Ft. 6 In. LOCATION West side of N Chester st

"A" P/S READING .20 TOTAL ANODES 1\* 0 17\* 0 L.R. # \_\_\_\_\_

REMARKS: Rectifier out



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY