

LOCATION 807 S CHESTER

CITY EAST.

BETWEEN GARRISON BLVD.

STREET &

TENTH ST.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	47'			
MAIN TO PROP. LINE	"	"	8'			
PROP. LINE TO BLDG.	"	"	3.5'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4"

PRESSURE 60 PSI

INCHES W.C.

LOCATION 179' From C of
GARRISON BLVD.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DIL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1997


DEPTH: 3 FT. 0 IN. LOCATION West side of S CHESTER

"A" P/S READING P

TOTAL ANODES 1# - 17# -

L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY