

CITY East.

STREET & Tenth St.

STREET

ENTERS: *SAME*

BRANCHED INTO:

PRESSURE 60 PSI

INCHES W.C.

LOCATION 433' from (6) of

FAIRISON Blup.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H.J.

MAIN-SIZE <u>2"</u>	C.I. _____	BARE STEEL _____	COATED STEEL _____	PLASTIC <input checked="" type="checkbox"/>	YEAR INSTALLED <u>1992</u>
---------------------	------------	------------------	--------------------	---	----------------------------


DEPTH: 3 FT. 0 IN. LOCATION west side of CHESTER ST

"A" P/S READING 2.

TOTAL ANODES 1# — 17# —

L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY