

LOCATION 821 S CHESTER ST. CITY EAST.

BETWEEN GARRISON BLVD STREET & TENTH ST. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>24'</u>			<u>5-6-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>9'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>15'</u>			

ENTERS: SAME BRANCHED INTO: 819 S CHESTER ST.

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 523' FROM @ OF

GARRISON BLVD


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DWF

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 FT. 0 IN. LOCATION WESTSIDE OF S CHESTER.

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY