

LOCATION 825 S CHESTER ST.CITY PAST.BETWEEN GARRISON BLVD.STREET & TENTH ST.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>73'</u>			<u>5-6-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>65'</u>			

ENTERS: SAME


BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI

INCHES W.C.

LOCATION 646' From @ ofGARRISON BLVDPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AKJMAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN. LOCATION West side of CHESTER"A" P/S READING P. TOTAL ANODES 1# — 17# — I.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY