

LOCATION 833 S CHESTER ST. CITY CAS.

BETWEEN TENTH ST. STREET & GARRISON BLVD STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>97'</u>		<u>5-7-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>8'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>89'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI        INCHES W.C. LOCATION 393' from @ of

TENTH ST.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DHL

MAIN-SIZE 2" C.I.        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION Westside of S Chester St.

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<b>S</b>	
	P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY