

LOCATION 839 S CHESTER ST.

CITY GAST.

BETWEEN TENTH ST.

STREET &amp; BARRISON BLVD

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P.	58'		5-8-97	
MAIN TO PROP. LINE	"	"	6'			
PROP. LINE TO BLDG.	"	"	52'			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 275' from O DF Tenth St.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DJJ

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION Westside of S Chester St.

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY