

LOCATION 204 Chestnut LN CITY GAstonia

BETWEEN mt OAK LN STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>140'</u>	<u>10/3/96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>15'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>125'</u>			

ENTERS: 204 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 PSI INCHES W.C. LOCATION West side of 204


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC — YEAR INSTALLED 1987

DEPTH: 2 FT. 6 IN. LOCATION South side of mt OAK LN

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 536996

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY