

LOCATION 211 S. Chestnut CITY CASHTONIA
BETWEEN Franklin Blvd. STREET & Second Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>11-8-93</u>	<u>26' Existing</u>	<u>Tied over 185'</u>
MAIN TO PROP. LINE					<u>3/4 CFW</u>	<u>Existing 3/4</u>
PROP. LINE TO BLDG.						<u>CFW</u>

ENTERS: 211 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 122' W. of C of 2nd Ave.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In. LOCATION 17' E of C of Chestnut St.

"A" P/S READING P TOTAL ANODES 1* 1 17* — L.R. # —

REMARKS: Tied Tracer wire OFF At Tee. Bonded Dresser
Anode installed. Reading .40 Before Anode .85 after Anode installed.

~~Bare Main Replacement~~
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser .85
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY