

LOCATION 313 S. CHESTNUT ST. CITY GASTONIA
BETWEEN E. PRICE ST. STREET & 3RD ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>88'</u>	<u>11-23-93</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>48'</u>			

ENTERS: 313 BRANCHED INTO: _____
TAP SIZE: 3/8 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION SOUTH SIDE OF 313

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BA
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1952
DEPTH: 3 Ft. 0 In. LOCATION 77' SOUTH OF PRICE / 12' NORTH OF C OF

"A" P/S READING 85 TOTAL ANODES 1* 0 17* 0 L.R. # 00455815

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY