

LOCATION 327 S. ChestnutCITY EastonBETWEEN 2ndSTREET & 3rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>115</u>		<input checked="" type="checkbox"/>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>40</u>			<u>8-17-96</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>75</u>			

ENTERS: 327BRANCHED INTO: 0TAP SIZE: 1"

PRESSURE

40

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @

105

psi

For

1/4

Hrs.

By

EP

MAIN-SIZE

4"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1957

DEPTH:

3

Ft.

In.


LOCATION

"A" P/S READING

6.1TOTAL ANODES 1# 0 17# 0

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY